WATERSYSTEMS CLEANING
TOWER & SCRUBBER SOLUTIONS

Phone : (408) 320-6880
Email : info@wscnc.com
Website : www.wscnc.com

Customer		Crew Chief	
Equipment I.D.		Work Order No.	
MFG		Belts Size and QTY	
Type of Service	☐ Quarterly ☐ Semi-Ann ☐ Annual	Date of Serviced	

QUARTERLY/SEMI ANNUAL SERVICE

		COMMENTS
Check with operating or area personnel for deficiencies.	☐	
Check operation of the unit for water leaks, noise or vibration.	☐	
Clean and inspect hot water basins or nozzles and manifolds.	☐	
Remove the access panel.	☐	
Check electrical wiring and connections, make appropriate adjustments.	☐	
Lubricate all motor and fan bearings.	☐	
Check fan blades or blowers for imbalance tip clearance.	☐	
Check belt for wear, tension and alignment; adjust as required.	☐	
Drain and flush cold-water sump and clean strainers.	☐	
Clean inside of tower using water hose; scrape, brush and wipe as required.	☐	
Refill with water, check makeup water assembly leakage; adjust the float if necessary.	☐	
Replace access panel.	☐	
Remove clean and reinstall conductivity and pH electrodes in chemical water treatment system.	☐	
Inspect and clean around the cooling tower.	☐	

ANNUAL SERVICE

		COMMENTS
Performed all semi-annual services above.	☐	
Lubricate all motor and fan bearings.	☐	
Clean air intake louvers, surface fill and drift eliminators.	☐	
Clean pump heads.	☐	
Inspect and clean spray nozzles and manifolds.	☐	

ADDITIONAL COMMENTS: